

This section includes AMBICO Bullet Resistant Steel Door Overhead Door Assemblies which meet the UL752 “Standard for Bullet-Resisting Equipment”. This section relies on both the Canadian Steel Door Manufacturers Association (CSDMA.org) industry standard, as well as on the Hollow Metal Manufacturers Association (NAAMM.org) industry standard for steel doors. This section includes proprietary, descriptive and performance type specifications. Edit to avoid conflicting requirements.

Part 1 General

1.1 SECTION INCLUDES

This article includes a summary of the content of this section which will not be included in other sections. This article is NOT intended to be used as a trade or other form of jurisdictional content.

- .1 Bullet Resistant steel overhead doors [and panels].
- .2 Factory- supplied overhead door hardware.
- .3 Factory supplied electric door operators.
- .4 Factory supplied [and installed] bullet resistant glass and glazing.

Bullet resistant glazing can not be supplied on a fire rated bullet resistant assembly.

- .5 [Bullet-resistant glazing.]

1.2 RELATED SECTIONS

This article references other specification sections that inter-rely on this section. This listing should include those sections that describe subjects or products that affect this section directly.

- .1 Section [_____ - _____]: Masonry mortar fill of metal frames.
- .2 Section 05 50 00 - Metal Fabrications: Steel channel frame.
- .3 Section 07 92 00 - Joint Sealing: Caulking between frame and adjacent construction.
- .4 Section 08 10 00- Steel Frame: to suit metal door and operator.
- .5 Section 09 91 15 - Painting: Field painting of doors.
- .6 Section 26 05 20-Wire and Box Connectors: Electrical wiring, conduit and disconnects.

1.3 REFERENCES

List reference standards that are included within the text of this section. Delete references that do not apply to this project.

- .1 ASTM A36/A36M-05 - Standard Specification for Carbon Structural Steel.
- .2 ASTM A653/A653M-06 - Standard Specification for Steel Sheet, Zinc-Coated (Galvanized) or Zinc-Iron Alloy-Coated (Galvannealed) by the Hot-Dip Process.
- .3 AISC 325-17 - AISC Steel Construction Manual.

- .4 ULC 752-05 - Standard for Bullet Resisting Equipment.

1.4 PERFORMANCE REQUIREMENTS

Include this article if all doors should meet the same bullet resistant requirement; otherwise, specify individual performance for door types in Part 2 or in a schedule. AMBICO overhead door assemblies can be manufactured to meet the bullet resistant requirement of handguns as well as high powered rifles.

- .1 Bullet Resistance: Conform to UL 752, Level [1] [8] [].

1.5 SUBMITTALS

- .1 Section [01 33 00]: Submission procedures.
- .2 Product Data: Provide product data on door construction and [_____].
- .3 Shop Drawings: Indicate door elevations, internal reinforcement, closure methods, [finishes,] location for hardware, and cut-outs [for glazing].
- .4 Test Data:
- .1 Submit independent test data from a recognized licensed laboratory indicating compliance with the ballistic performance requirements.
- .2 When bullet resistance is not supported by prototype tests, design calculations by a licensed professional engineer shall be accepted.

Include the following ONLY if specifying for a LEED project. Specify only the technical requirements necessary to achieve the credits desired for this project. AMBICO products offer significant advantages to firms interested in supporting LEED certification

- .5 Sustainable Design:
- .1 Section 01 35 18: LEED documentation procedures.
- .2 Provide required LEED documentation for Product.
- .3 Manufacturer's Certificate: Certify that Products meet or exceed [specified requirements].
- .1 Closeout Submittals
- .2 Section 01 78 10: Submission procedures.
- .3 Operation and Maintenance Data:
- .4 Include electrical control adjustments.
- .5 Include data for [motor] [transmission] [shaft and gearing] [lubrication frequency] [spare part sources].
- .3 Warranty Documentation: Submit manufacturer warranty and ensure forms have been completed in Owner's name and registered with manufacturer.

Include the following ONLY if specifying for a LEED project.

.4 Sustainable Design Closeout Documentation: [_____].

.7 Installation Instructions: Submit manufacturer's installation instructions.

1.6 QUALITY ASSURANCE

.1 Manufacturer: Minimum 5 years documented experience manufacturing Bullet Resistant Steel Overhead Door Assemblies.

.2 Manufacturer: Minimum 5 years documented experience manufacturing Bullet Resistant Steel Overhead Door Assemblies.

.3 Pre-installation Meeting: Convene a pre-installation meeting [2] [___] weeks before start of installation of door, door hardware and operator assemblies. Require attendance of parties directly affecting work of this section, including contractor, architect, installer, and manufacturer's representative. Review installation and coordination with other work.

1.7 DELIVERY, STORAGE AND PROTECTION

.1 Section [01 61 00]: Transport, handle, store, and protect products.

.2 Remove door panels, door hardware and operators from wrappings or coverings upon receipt on site and inspect for damage.

.3 Store in vertical position, spaced with blocking to permit air circulation between components.

.4 Store materials out of water and covered to protect from damage.

.5 Clean and touch up scratches or disfigurement caused by shipping or handling with zinc-rich primer.

1.8 WARRANTY

.1 Manufacturer's Limited Warranty: Five (5) years from date of supply, covering material and workmanship.

Part 2 Products

2.1 MANUFACTURERS

List the manufacturers acceptable for this project. Edit the subsequent descriptive specifications of Part 2, to identify project requirements and to eliminate any conflict with specified manufacturer's products.

.1 AMBICO Limited
1120 Cummings Avenue
Ottawa, Ontario, Canada K1J 7R8
Toll Free Phone 888-423-2224
Phone 613-746-4663

Toll Free Fax 800-465-8561
 Fax 613-746-4721

- .2 Other Acceptable Manufacturers:
- .1 [_____].
- .2 [_____].
- .3 Substitutions: [Refer to Section 01 60 00.] [Not permitted.]

2.2 MATERIALS

- .1 Sheet Steel: Galvanized steel to ASTM A653/A653M.
- .1 Coating designation [Z275] [ZF75] ([G90]) ([A25]) ([]) for exterior door assemblies.
- .2 Coating designation [ZF001] ([A01]) for interior door assemblies.
- .2 Reinforcement [Channel]: To CSA G40.20/G40.21, coating designation to ASTM A653/A653M, [ZF75] ([A25]).
- .3 Structural Plate: Hot rolled steel to ASTM A1011.

2.3 ACCESSORIES

AMBICO Bullet Resistant Steel Overhead Door Assemblies are supplied with overhead door hardware and electric operators as an integral part of the tested assembly. All other accessories specified in this section shall be supplied by the door manufacturer.

- .1 [Glazing Stops: Formed galvanized steel channel, [butted] [mitred] corners; prepared for countersink style [tamperproof] screws.]
- .2 [Glass: Type as tested to achieve bullet resistant performance ratings. Glazing to be factory supplied [and preinstalled].]
- .3 Weight Box: shall be constructed from structural steel members. Counterweight shall have internal angle guides to enclose and guide the counterweights for the full travel. The weight box shall be braced at the building structure by the door erector.
- .4 Guide Assembly: Shall be constructed from structural steel members with base and guide covered with 1/4" thick steel plate. The guide assembly shall be braced at the building structure by the door erector.
- .5 Guide Angles: Door blades will ride on a continuous vertical structural steel angle and guides and shall not be less than 1/4" in thickness. The guide angles will be welded to the to the weight box and guide assembly. The weight box and guide assembly shall be braced at the building structure by the door erector on 48" (1200 mm) centers.
- .6 Section Guides: Each door section shall have continuous member that shall mate with the guide angles. The section guides shall be bolted to the door section for easy field installation or replacement removal of the sections.

- .7 Insulation of Weight boxes and Guides: Exposed surfaces of the weight boxes and guides shall be insulated with 1" thick polyurethane insulation and shall be back sheeted with 18 gage galvanized steel sheet.
- .8 Weatherstripping: The vertical weatherstripping shall be combination aluminum retainer and nylon brush set over insulation of the weight box and guides cover.
- .9 Multi-blade model # 45 Drive and Counterbalancing Mechanism: positive frictionless drive will consist of machined cable sheaves and steel sprockets mounted on a solid cold rolled steel shaft. All rotating elements will rotate on a heavy duty, grease-packed-for life, self-aligning flange bearing. The drive unit will be modular and will be mounted in a removable heavy gage drive housing. For maximum safety two cables shall be provided for each section as well as two roller chains for the bottom section. The drive and idler housings will be seated and bolted to the weight box and door guide assemblies for easy servicing. Counterweight sets will be suspended by heavy duty roller chains and preformed galvanized cables assuring the smooth travel of each door blade in both the upward and downward direction. Steel pick up members with rubber chock absorbing cushions on the top of each section will ensure smooth and silent operation. Roller chain and cables will be selected to provide 7:1 safety factor and shall be equipped with blade levelling screws.
- .10 Safety Catches: in the case of a cable failure the upper blades will be equipped with heavy duty factory welded catches. The safety catches will prevent the upper sections from falling further than the section immediately below.
- .11 Fail-Safety Device: The door will be equipped with a fail safety device that will provide the following features:
 - .1 Instantly locking bottom section into both weight box and guide when one or both counterweight chains are broken or slacked
 - .2 Instantly cuts power to the motor preventing further damage.
 - .3 Maximum permissible engagement is 6 inches.
 - .4 Eliminates the need for side locks.
- .12 Primer: Rust inhibitive zinc phosphate.

2.4 FABRICATION

- .1 Manufacture doors and frames to Level [1] [8] [] bullet resistance rating in accordance with UL 752.
- .2 Steel Doors, Overhead Door Type:
 - .1 Sheet steel faces, thickness, design, and core suitable to achieve specified bullet resistant performance.
 - .2 Bullet resistant construction, mechanically inter-locked shall be welded, filled and sanded with visible edge seams.
 - .3 Top and Bottom Channels: shall be full width and shall form a ship-lap joint between sections.
 - .4 Weld structural steel channels flush to top and bottom of door.
 - .5 Weld hardware reinforcement plates in place.

- .3 Affix permanent metal nameplates to door and frame, indicating manufacturer's name, door tag, model number, and ballistic performance rating.

2.5 ELECTRICAL SPECIFICATIONS

Electrical operators shall be supplied by the Bullet Resistant steel door manufacturer and shall be an integral part of the Bullet Resistant Steel Overhead Door Assembly.

- .1 Electric Operator: The electric operator shall have the following characteristics:
 - .1 The unit shall be UL approved.
 - .2 The unit shall be rated at Class I, Division II, Group [C][D]. Installation shall be in conformance with NEC.
 - .3 The unit shall have a heavy-duty worm-gear reducer with a standard NEMA "C" flange. A minimum 220 volt, 3 phase motor is required and it shall be TEFC.
 - .4 Electromechanical brake
 - .5 Rotary screw type limit switches
 - .6 Manual operation chain hoist.
 - .7 Electrical interlock for manual operation.
 - .8 Door speed 8"-10" per second.
- .2 Door Controls and Electrical Equipment
 - .1 The door control shall have integral piggyback control panel.
 - .2 The door shall have a separate control panel located at the ground level. This panel shall be provided by Section 26 05 20 –Wire and box connectors: Electrical wiring , conduit and disconnects.
 - .3 The door controls shall be housed in a Class I, Division II, metal box.
 - .4 The controls will include a heavy duty reversing starter.
 - .5 Thermal overload relays.
 - .6 Control relays.
 - .7 Time delay on reversing.
 - .8 Timer to close the door.
 - .9 Miller reversing safety bar on the bottom of the door.
 - .10 Additional protective urethane rubber hood over the Miller safety bar.
 - .11 16 gage SOW coiled cord for revering safety bar.
 - .12 Control interface and interlock with any third-party system.

2.6 PRE-INSTALLATION OF GLAZING

- .1 Glazing shall be designed in conformance with 1.4.
- .2 Glazing shall be factory supplied [and pre-installed] [and shipped loose ready for site installation by others].

2.7 FINISHES

- .1 Factory Finish: Factory applied zinc phosphate primer [to be applied to all exposed surfaces] [touch-up only, where product has been welded and ground smooth].

- .2 Finish Painting: finish painting shall be by Section 09 91 00

Part 3 Execution

2.8 INSTALLATION

- .1 Install components in accordance with manufacturer's written instructions.
- .2 [Install factory supplied glazing to door panels.]
- .3 Coordinate with [masonry] [gypsum board] [concrete] [_____] wall construction for anchor placement.
- .4 Allow for deflection to ensure that structural loads are not transmitted to frame.
- .5 Brace weight box and guide assembly to the building structure at 1200 mm (48 inch) centres.
- .6 Adjust operable parts for correct clearances and function.
- .7 Finish paint in accordance with Section 09 91 00.

2.9 FIELD QUALITY CONTROL

- .1 Provide qualified manufacturer's representative to instruct installers on the proper installation and adjustment of door assemblies. Field supervision shall be conducted on-site by factory personnel during the initial installation period. Final commissioning of bullet resistant, steel overhead door assembly shall occur in the presence of factory personnel.
- .2 Provide manufacturer's representative to inspect door installation, and test minimum five (5) cycles of operation. Correct any deficient doors.

END OF SECTION